

DECLARATION OF PERFORMANCE

according Annex III of the Regulation (EU) No 305/2011

Mach 9th 2011

Name of the product: Mixed Penetration Seal "BARRAFlame DMA/DMK – 2.50"
No. 0761-CPD-0268

1. Unique identification code of the product-type:

Mixed penetration seal "BARRAFlame DMA/DMK – 2.50" based on the intumescent components Fire Stop Coating "BARRAFlame DMA" and Fire Stop Mastic "BARRAFlame DMK"

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

See ETA – 11/0113;
See type, batch or serial number on packaging of the product.

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

Mixed penetration seal for maintaining the fire resistance of sealed apertures in light weight, plasterboard walls, rigid walls and floors carrying various service penetrations like cables, electrical installation conduits, plastic pipes, metal piping and cable support constructions.

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

BASF Personal Care and Nutrition GmbH

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

Not relevant

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

Not relevant

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

OIB, Austrian Institute of Construction Engineering issued European Technical Approval ETA – 11/0113 on the basis of ETAG No. 026, the notified body MPA (Materialprüfanstalt für das Bauwesen).

TU Braunschweig performed third party tasks as set out in Annex V under System ... and issued Certification of Conformity 0761-CPD-0268.

DECLARATION OF PERFORMANCE

according Annex III of the Regulation (EU) No 305/2011

Mach 9th 2011

Name of the product: Mixed Penetration Seal "BARRAFlame DMA/DMK – 2.50"
No. 0761-CPD-0268


9. Declared performance

Essential characteristics	Performance / Harmonised technical specification
Reaction to fire	class B-s1, d0 according to EN 13501-1
Resistance to fire	Resistance to fire performance and field of application in accordance with EN 13501-2, see ETA – 11/0113
Durability and serviceability	Z ₂ , according to ETAG 026 - Part 2
Safety in use (Mechanical resistance and stability)	not relevant, no performance determined
Hygiene, Health, Environment (air tightness, water tightness, dangerous substances)	see ETA – 11/0113, point 2.4 and MSDS
Protection against noise	see acoustic evaluation test report no. 12129.2
Energy resistance and stability	no performance determined

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Robert Graf / Business Manager
 (name and function)


 (signature)

Maria-Elisabeth Kaiser / Product Management
 (name and function)


 (signature)

Illertissen, May 2nd 2014
 (place and date of issue)